




Product Service

CERTIFICATE

No. Z2 120808 0002 Rev. 00

Holder of Certificate: **G-STAR PTE. LTD.**
6 RAFFLES QUAY #14-06
Singapore 048580
SINGAPORE

Certification Mark:



Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-Crystalline Silicon Photovoltaic Module

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262310302-00

Valid until: 2028-07-06

Date, 2023-07-11

(Zhulin Zhang)



CERTIFICATE

No. Z2 120808 0002 Rev. 00

Model(s): GSY7072M-xxxBW (xxx=555-600, in steps of 5)
 GSY7054M-xxxBB (xxx=410-440, in steps of 5)
 GSY7054M-xxxBW (xxx=420-450, in steps of 5)
 xxx is standing for rated output power at STC.

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors.
Safety Class:	Class II
Maximum System Voltage:	1500 V DC
Fire Safety Class:	Class C according to UL790
PID Test Condition:	Test method a of IEC TS 62804-1:2015, ±1500V DC, 192 hrs, 85 % RH, 85 °C.

Tested according to:

PPP 58042B:2015
 IEC 61215-1:2016
 IEC 61215-1-1:2016
 IEC 61215-2:2016
 IEC 61730-1:2016
 IEC 61730-2:2016